

THE PORT AUTHORITY OF NEW YORK AND NEW JERSEYM E M O R A N D U M


TO: Robert Linn, Deputy Director for Physical Facilities, World Trade
FROM: Najib A. Budeiri & Economic Development
DATE: June 10, 1987
SUBJECT: WORLD TRADE CENTER ASBESTOS SIGNING PLAN

REFERENCE: Memo; R. Linn to N. Budeiri, dated 5/5/87, same subject

COPY TO: F. Boyce, T. Cancelliere, J. Carlock, D. Cupelli, R. Fagin, M.D.,
M. Kirschner, D. MacIntyre, D. Montalbano, H. Pool, Jr., A. Preschle,
S. Samperi, V. Vaccaro

As requested in the referenced memo, the wording of the asbestos warning sign which is intended to be used in the World Trade Center Mechanical Equipment Rooms was reviewed. The opinion of this office is that the proposed sign is informative and clear.

Your memo references two OSHA Standards: Hazards Communication standards 29 CFR 1910.1200, and 29 CFR 1926.59. OSHA Standard 1910.1200 covers chemical exposures, and 1926.59 requires specific language when the airborne asbestos level exceeds the permissible exposure limit. Since this sign is intended to be used as a cautionary alert to the workers, these standards should not be referenced. In addition, the contents of this sign should be reviewed by the Law Department prior to its use.



Najib A. Budeiri, Manager
Inspection and Safety Division

/daw

M 026523

M E M O R A N D U M

TO: F. Boyce, N. Budeiri, T. Cancelliere,
J. Carlock, D. Cupelli, M. Kirschner,
D. MacIntyre, D. Montalbano, A. Preschle,
S. Samperi, A. Vaccaro
FROM: R. Linn
DATE: May 5, 1987
SUBJECT: WTC Asbestos Signing Plan
cc: File

Please review and comment on the attached asbestos signing plan for WTC mechanical equipment rooms.

It is intended to warn maintenance and construction workers of the presence of asbestos in such areas as well as satisfy OSHA HAZARDS COMMUNICATION STANDARD 29 CFR 1910.1200 and OSHA CONSTRUCTION STANDARDS 29 CFR 1926058 SECTION K COMMUNICATION OF HAZARDS TO EMPLOYEES.

Please send your comments to D. MacIntyre by 6/8/87.

Robert J. Linn
Deputy Director for
Physical Facilities
World Trade & Economic Development

Att.

Asbestos Signing Plan

bcc: DM/n-

RECEIVED
MAY 11 1987
P2:20

M026524

20,153 2

W.T.C.
Asbestos Signing Plan

Elevator pits

- 23 shuttle car pits
- 48 local car pits
- 15 various locations (i.e. J&K cars etc.)

MER

subgrade 8-6 level

- 1 sign Rear stairway from refer plan to pipe gallery
- 2 sign 2 entrances from pipe gallery to T.A. MER
- 1 sign entrance to MER from K-1 stairway
- 1 sign entrance to MER from J car elevator
- 1 sign in area of 8-6 welding shop
- 1 sign on main steam meter room cage
- 1 sign off K-2 car 8-6 level to pipe gallery
- 1 sign from stairway of refer plan to pipe gallery
- 1 sign entrance door to pipe gallery from K-4 stairway
- 1 sign T.B. MER entrance from K-4 stairway
- 1 sign T.B. MER entrance from K car elevator's

7th fl. T.A.

- 1 sign outside 50 car gate
- 1 sign outside 5-48 car gate (Common gate)
- 2 sign inside stairway doors A & B

41 fl. T.A.

- 1 sign outside 50 car gate
- 1 sign outside 49 & 17 car gate (common gate)
- 3 sign inside stairway doors (A, B, C stairway)
- 2 sign for doors on 42 above substations

25th fl. T.A.

- 1 sign outside 50 car gate
- 1 sign outside 6 car gate
- 3 sign inside stairway doors (A, B, C stairways)
- 2 signs for doors on 26 above substations

108th fl. T.A.

- 1 sign inside stairway doors - (A & C stairways)
- 2 sign for entrance doors to MER & off 50 car

7th fl. T.B.

- 1 sign outside 50 car gate
- 1 sign outside 5-49 car gate
- 1 sign inside stairway doors (A & B stairways)

41st fl. T.B.

- 1 sign outside 50 car gate
- 1 sign outside 49 & 17 car gate (common gate)
- 3 sign inside stairway doors (A, B, C stairways)
- 2 signs for doors on 42 above substations

75th fl. T.B.

- 1 sign outside 50 car gate
- 1 sign outside 6 car gate
- 1 sign inside stairway doors (A, B, C stairways)
- 2 signs for doors on 76 above substations

108th fl. T.B.

- 2 sign inside stairway doors (A & C stairways)
- 2 sign for entrance door to MER's off 50 car